

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES	
				J	1	2
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 25-Sep-2004	4. REQUISITION/PURCHASE REQ. NO. W68MD9-4258-0946		5. PROJECT NO.(If applicable)		
6. ISSUED BY USA ENGINEER DISTRICT, SEATTLE ATTN: CENWS-CT 4735 EAST MARGINAL WAY SOUTH SEATTLE WA 98134-2329	CODE W912DW	7. ADMINISTERED BY (If other than item 6) USA ENGINEER DISTRICT, SEATTLE ANGELA DEXTER PH: 206-764-6801 FAX: 206-764-6817 ANGELA.DEXTER@US.ARMY.MIL SEATTLE WA		CODE	W912DW	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. W912DW-04-Q-0186	
				X	9B. DATED (SEE ITEM 11) 21-Sep-2004	
					10A. MOD. OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.						
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) W912DW-04-Q-0186, TEMPERATURE AND FLOW GAUGE, BRIDGEPORT WASHINGTON The purpose of this amendment two (0002) dated 25 September 2004 is to address question pertaining to this project. SEE CONTINUATION PAGE						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED		
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		25-Sep-2004		

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

NOTES

1.. The purpose of this amendment two (0002) is to address questions pertaining to this project follows:

A. Question: The request line item 0002 calls for the unit of measurement of the dial range to be in GPM. Please verify this unit is correct and not PSI (Pounds Square Inch).

RESPONSE: The required flow meters are a low pressure GPM differential pressure gauge. The gauge measures the differential pressure but indicates flow in gallons per minute (GPM) per table 1 of the amendment. We are measuring cooling water flow through various parts of our generators and need to know flow in GPM per the original equipment manufacturers operating instructions.

B. THE CLOSING DATE AND TIME REMAINS THE SAME.

C. Offerors must acknowledge all amendments by date and number.