

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 20-May-2003	4. REQUISITION/PURCHASE REQ. NO. W68MD9-3126-3087		5. PROJECT NO.(If applicable)
6. ISSUED BY USA ENGINEER DISTRICT, SEATTLE ATTN: CENWS-CT P.O. BOX 3755 SEATTLE WA 98124-3755		CODE DACA67	7. ADMINISTERED BY (If other than item 6) SEATTLE DIST, CORPS OF ENGRS PATTY ORTIZ 206-764-3516 SEATTLE WA 98124-3755		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. DACA67-03-Q-2011	
			X	9B. DATED (SEE ITEM 11) 13-May-2003	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.					
<p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Solicitation Number: DACA67-03-Q-2011 Project Title: Installation of Parking Lot Lighting, White Bluff Complex Location: Spokane, Washington See Continuation Sheet					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) ELAINE M EBERT / CONTRACTING OFFICER TEL: (206) 764-6698 EMAIL: elaine.m.ebert@usace.army.mil		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 20-May-2003

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

SECTION B - SUPPLIES OR SERVICES AND PRICES

1. The purpose of this amendment one (0001), dated 20 May 2003, is to delete the Scope of Work in its entirety and replace it with the revised Scope of Work, dated 20 May 2003.

2. **THE CLOSING DATE AND TIME REMAINS UNCHANGED AS FOLLOWS:**
28 MAY 2003, 1:00 P.M. LOCAL TIME.

3. Offerors must acknowledge this amendment by date and number.

Parking Lot Lighting Scope of Work

JPRTF, White Bluff Complex

12 May 2003

Revised 20 May 2003

1. General Scope of Work.

a. Base bid: Install (four) 4, twenty-five foot (25') light poles. Light poles are to be mounted on a pole base as described in 100 percent "For Construction" drawings (Plate E7.1, detail 5) in existing parking lot at stub-out locations.

b. Optional Bid Item: Involves four (4) poles total on Northwest perimeter of parking lot. Install 3 new -twenty five-foot (25') light poles with pole bases as described in 100 percent "For Construction" drawings (Plate E7.1, detail 5). The fourth pole is already installed and supports a perimeter security camera. This pole will require only a mounted shoebox light fixture with accompanying power source.

2. Referenced Material for the Contractor.

a. Existing condition photos (furnished by separate PDF File).

b. Parking lot lighting site plan sketch.

c. JPRTF 100% design drawings E1.1, E1.2 and E7.1

3. Detailed Scope of Work.

a. JPRTF Parking Lot Lighting, Base Bid With One Option. Provide estimate to install four base bid item (and 3 optional bid item light poles and one installed shoebox light fixture) in accordance with JPRTF White Bluff 100% building design for construction plate E1.1, E1.2 and E7.1. Attached PDF labeled "Parking Lot Lighting" (parking Lot lighting plan sketch) has base bid light poles highlighted in yellow and an option bid item for 3 additional light poles plus one installed fixture all highlighted in green. Electrical conduits stubbed at ground level are provided for the base bid light poles. Electrical conduits without wire are in place for all 4 optional poles. A pedestal power source with empty conduits will be provided and installed by the Government in a separate work item (not part of this contract work) to wire the optional bid item 1 poles. The power source for the optional poles will be midway between the double shoebox light pole and the single shoebox light pole highlighted in green. Install all light poles on unfinished smooth finished concrete bases. Ensure all base bid light fixtures are 277 VAC. Ensure all optional light fixtures are 120/208 VAC.

b. All base and optional light fixtures shall be high-pressure sodium clear (in lieu of the metal halide indicated on drawing E 1.2). Provide the unpainted smooth-finished concrete bases set with the top 30-inches above grade. Provide the Lithonia KSF2 Series lighting or approved equal (indicated on drawing E 1.2). Provide 4-inch (4") square, steel (or 6" square aluminum) poles (tall enough to position light fixture lens approximately 27.5 feet high measured from the ground instead of the 35 feet height indicated on drawing E1.2) with powder coated dark bronze finish. For the base bid, reference drawing E 1.2 fixture schedule, 2 light poles will support single shoe-box fixtures identified as AH1; and 2 remaining poles will support dual shoe-box fixtures identified as AH2.

- c. For the optional 4 light poles (indicated in green highlights on attached PDF sketch). As with the base bid parking lot light poles, existing conduit is also in place to serve the optional light poles as well. Three of the new 25-foot high new light poles will also all have unfinished concrete bases and their associated fixtures shall match the criteria indicated in paragraph 3b. This 4th - 25-foot pole is already installed and contains an existing security camera (already wired for the security camera via a different independent power source, unrelated to the proposed power source under this contract for all optional pole lights). This existing 25-foot tall security camera pole requires a shoebox light fixture. As indicated in green on the PDF site sketch, 3 of these optional bid item poles will support single shoe-box fixtures identified as AH1 (AHU 1 designated in the parking lot) and the 1 remaining pole will support a dual shoe-box fixture identified as AH2 (AHU 2 as designated in the parking lot). The existing 25-foot high camera pole already has an additional set of power conduits installed to support installation of 120/208-volt wire for the light fixture.
- d. Submit for Government approval before construction product literature/catalog cut sheets of the poles and fixtures.
- e. As-built drawings of the lighting poles and fixtures are not required.
- f. Test the lights during night time conditions with the Government participation.
- g. Ensure failure of one or more lights does not affect the operation of remaining lights.
- h. Coordination with the proposed paving contractor may be required to install the parking lot lights; the Government will facilitate coordination.
- i. The four parking lot curbing islands shown on drawings E1.1 and E1.2 and also shown in the parking lot lighting site plan sketch have been deleted from the project. These parking lot curbing islands will be replaced with pavement to create additional parking spaces, in the proposed pavement contract.

End SOW