

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES	
				J	1	2
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 28-Feb-2003	4. REQUISITION/PURCHASE REQ. NO. W68MD9-2339-3168		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, SEATTLE ATTN: CENWS-CT P.O. BOX 3755 SEATTLE WA 98124-3755		CODE DACA67	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. DACA67-03-R-0206	
				X	9B. DATED (SEE ITEM 11) 07-Feb-2003	
					10A. MOD. OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Solicitation No. DACA67-02-R-0206 Amendment No. R0004 Title: FIRE ALARM INSPECTION, TESTING AND MAINTENANCE FORT LEWIS, WASHINGTON CONTINUATION SHEET						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		03-Mar-2003	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The purpose of this Amendment No. R0004, to RFP/Solicitation No. DACA67-03-R-0206, entitled "Fire Alarm System Inspection, Testing and Maintenance at Fort Lewis, Washington," is to reissue the enclosures incorporated by Amendments R0001 and R0003 for identification purposes only, replace Section B/the Bid Schedule and Sheet 4 of Appendix D to Section C-Statement of Work and include as enclosures the Preproposal Site Visit Attendance sign in sheet, Minutes of the site-visit and answers to the questions presented by the attendee's of the site visit.

1) The Cover or Title Page, Site Visit Information page and Corporate Certificate are reissued to incorporate "R0001" at the bottom of the page for identification purposes only. The Announcement to Bidders/Offerors, Caution to Offerors, and Customer Satisfaction Survey are reissued to incorporate "R0003" at the bottom of the page for identification purposes only. There are no other changes to these pages.

2) **Section B/Bid-Schedule is hereby deleted and replaced in its entirety.** The revised Bid-Schedule hereby incorporated into the above noted RFP/Solicitation has three (3) Optional Line Items added to correspond with the changes made to Sheet 4 of Appendix D to Section C-Statement of Work.

3) **Section J, Appendix D to Section C-Statement of Work, d) Appendix D Exhibit – 4 (Pages C-D-4-1 thru C-D-4-12) is hereby deleted and replaced in its entirety.** Buildings are marked, under the Service Due Columns, with **X, 1, 2 or 3**. The corresponding location on the Section B/Bid Schedule is as follows: X – Line Item 1, No. 1 – Optional Line Item 3, No. 2 – Optional Line Item 4, No. 3 – Optional Line Item 5.

4) The Preproposal Site Visit Attendance Sheet is provided for informational purposes only. The Minutes of the Site Visit and answers to the questions presented by the attendee's of the site visit are provided for clarification and do not change the terms and conditions of the solicitation in any way.

5) **NOTICE TO OFFEROR:** Offeror must acknowledge receipt of this Amendment by number and date, on the Standard Form 33 in block 14, or by telegram.

6) The Time and Date that the Proposals are due for this Solicitation is not effected by this Amendment and remains unchanged at NLT 3:00 p.m. local time on 13 March 2003.

Enclosures:

Cover or Title Page (1Page)

Site Visit Information Page (1 Page)

Caution to Offerors (1 Page)

Announcement to Bidders/Offerors (1 Page)

Corporate Certificate (1 Page)

Customer Satisfaction Survey (2 Pages)

Revised Section B/Bid Schedule (10 Pages).

Revised Section J, Appendix D to Section C-Statement of Work, Exhibit –4 (12 Pages)

Preproposal Site Visit Attendance Sheet (1 Page)

Minutes of the Site Visit and clarification/answers to site visit attendee's questions (2 Pages)



**US Army Corps
of Engineers®**

Seattle District

Fire Alarm System Inspection, Testing and Maintenance

Services Solicitation and Specifications

**This is a 100% Small Business
Set-Aside**

February 2003

This page intentionally blank

THIS PROCUREMENT IS:

100% set-aside for Small Business

Site Visit:

- A one-time site visit for offerors is scheduled for **21 February 2003**. Bidders desiring to attend should arrive at the Visitors Center no later than **8:00 AM, Local Time**. Meeting is to be held at the U.S. Army Corps of Engineers Fort Lewis Area Office (FLAO), Building 2015 3rd floor, Fort Lewis, Washington. A temporary 1-day vehicle pass is required to drive on Fort Lewis and may be obtained from the Visitor's Center at the Fort Lewis Main Gate.
- To receive the temporary pass, at least six business days before the meeting is take place you must provide, the name of your company, names of the persons who will attend the meeting, Drivers License Numbers of the persons attending the meeting, and their date of birth (Information is to be submitted to Bill Byers, electronically at byersb@lewis.army.mil).
- When arriving at the Visitors Center, all visitors will present a valid drivers license, current vehicle registration, proof of insurance and state your destination on post (i.e. Corps of Engineers, Ft. Lewis Area Office). Visitors will have proof of insurance, vehicle registration, and drivers license at all times while driving on base.
- DIRECTIONS TO FORT LEWIS AREA OFFICE: Take I-5, to exit 121 (Fort Lewis/North Fort Lewis), follow the signs to Fort Lewis and proceed to the Visitor's Center, just inside and to the right of the Main Gate. After receiving a visitor pass, proceed onto the base on Division to the third traffic light. Turn right at the 3rd traffic light onto Pendleton Avenue. Building 2015 will be on the left at the blinking yellow light behind the Fire Station. Parking is available across the street from building 2015. The Area Office in on the 3rd floor.
- BIDDERS ARE URGED and expected to inspect the site where construction is to be performed and to satisfy themselves as to all general and local conditions which may affect the cost of performance of the contract, to the extent, such information is reasonably obtainable. In no event, will a failure to inspect the site constitute grounds for withdrawal of a bid after opening or for a claim after award of the contract.

FOR INQUIRIES, CONTACT THE FOLLOWING INDIVIDUALS Monday through Friday between the hours of 8:00 a.m. and 3:00 p.m.:

TECHNICAL MATTERS: Bill Byers, electronically : (byersb@lewis.army.mil)

Proposal Due Date & Time: 13 March 2003, NLT 3:00 PM Local Time

BIDDING DOCUMENTS: Register for solicitations at the Internet site: <http://www.nws.usace.army.mil/ct/>

PLANHOLDER'S LISTS: Lists may also be obtained from the same site.

ADMINISTRATIVE MATTERS: Kevin T Mulvihill

Phone Number: (206)764-6805

Internet:: (Kevin.T.Mulvihill@nws02.usace.army.mil)

FAX: (206) 764-6817

All individuals are at the following mailing and street addresses:
(Mail) Seattle District Corps of Engineers, P.O. Box 3755, Seattle, WA 98124-3755
(Street) 4735 E. Marginal Way S., Seattle, WA 98134-2385

DACA67-03-R-0206

This page intentionally blank

!!!CAUTION TO OFFERORS!!!

1. **TELEPHONES:** Limited telephone service is provided in the lobby. Only two public telephones may be used by offerors for completing offers.

2. **BUSINESS HOURS:** For the Seattle District Corps of Engineers are from 7:30 A.M. to 4:00 P.M., Monday through Friday.

BEFORE SIGNING AND MAILING THIS OFFER, PLEASE TAKE NOTE OF THE FOLLOWING, AS FAILURE TO PERFORM ANY ONE OF THESE ACTIONS MAY CAUSE YOUR OFFER TO BE REJECTED

3. **AMENDMENTS:** Have you acknowledged receipt of ALL amendments? If in doubt as to the number of amendments issued, please contact the Plans Room representative listed on the Information Page.

4. **AMENDED PAGES:** If any of the amendments furnished amended pages, the amended pages must be used in submitting your offer.

5. **MISTAKE IN OFFER:** Have you reviewed your offer price for possible errors in calculation or work left out?

6. **TELEGRAPHIC MODIFICATIONS:** The Seattle District does not have the capability of receiving commercial telegrams directly. Offerors who wish to modify their offer by telegram are urged to ensure that telegrams are submitted within enough time to arrive at the opening office prior to the time specified for receipt of proposals. Any doubt as to time should be resolved in favor of **EXTRA TIME.** Transmission by Fax to this office is **NOT ACCEPTABLE.**

7. **OFFER ACCEPTANCE PERIOD:** The minimum offer acceptance period is specified in block 12 Standard Form 33, Solicitation, Offer and Award. Please ensure that you allow at least the stated number of calendar days for the Government to accept your offer.

8. **CENTRAL CONTRACTOR REGISTRATION:** Your attention is drawn to DFARS Clause 252.204-7004, REQUIRED CENTRAL CONTRACTOR REGISTRATION in section I. Lack of registration in the CCR database will make offeror ineligible for award. Information on how to register and the time it takes are detailed in the clause.

9. **HUBZONE CERTIFICATION:** Your attention is drawn to FAR Clause 52.219-4, NOTICE OF PRICE EVALUATION PREFERENCE FOR HUBZONE SMALL BUSINESS CONCERNS (JAN 1999) in section 0600. A HUBZone small business concern, as used in this clause, means a small business concern that appears on the List of Qualified HUBZone Small Business Concerns maintained by the Small Business Administration.

Reference: <https://el.sba.gov:9000/prodhubzone/hubzone/approval.stm>

This page intentionally blank

ANNOUNCEMENT TO BIDDERS/OFFERORS

Due to recent national events Seattle District US Army Corps of Engineers shall be conducting business under heightened security for the foreseeable future.

Access to Federal Center South, 4735 E Marginal Way S, Seattle WA 98124 will be through the front Lobby only. The building is under Federal Protective Service, which means that persons entering the facility are subject to inspection; including purses, packages, etc. All deliveries shall be thoroughly inspected. In addition, visitors may be required to be escorted by Corps personnel while in the building.

Please allow sufficient time to deliver your bid/proposal so that it reaches the Contract Specialist by the required date and time.

For any questions please contact the Contract Specialist assigned to your project or check our website at www.nws.usace.army.mil for up-to-date information.

This page intentionally blank

IF THE CONTRACTOR IS A CORPORATION OR PARTNERSHIP, THE APPLICABLE PORTION OF THE FORM LISTED BELOW MUST BE COMPLETED. IN THE ALTERNATIVE, OTHER EVIDENCE MUST BE SUBMITTED TO SUBSTANTIATE THE AUTHORITY OF THE PERSON SIGNING THE CONTRACT. IF A CORPORATION, **THE SAME OFFICER SHALL NOT EXECUTE BOTH THE CONTRACT AND THE CERTIFICATE.**

CORPORATE CERTIFICATE

I, _____, certify that I am the _____ Secretary of the Corporation named as Contractor herein; that _____, who signed this contract on behalf of the Contractor was then _____ of said corporation; that said contract was duly signed for and on behalf of said corporation by authority of its governing body and is within the scope of its corporate powers.

(Secretary) (CORPORATE SEAL)

AUTHORITY TO BIND PARTNERSHIP

This is to certify that the names, signatures and Social Security Numbers of all partners are listed below and that the person signing the contract has authority actually to bind the partnership pursuant to its partnership agreements. Each of the partners individually has full authority to enter into and execute contractual instruments on behalf of said partnership with the United States of America, except as follows: (state "none" or describe limitations, if any)

This authority shall remain in full force and effect until such time as the revocation of authority by any cause whatsoever has been furnished in writing to, and acknowledged by, the Contracting Officer.

(Names, Signatures and Social Security Numbers of all Partners)

NAME	SIGNATURE	SOCIAL SECURITY NO.
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

This page intentionally blank

CUSTOMER SATISFACTION SURVEY (PAGE 1 OF 2)

FIRE ALARM SYSTEM INSPECTION, TESTING AND MAINTENANCE
 FORT LEWIS, WASHINGTON

DACA67-03-R-0206

SECTION 1 -- TO BE COMPLETED BY THE OFFEROR AND PROVIDED TO THE CUSTOMER REFERENCE

Name of Firm Being Evaluated: _____

Project Title & Location: _____

Project Dollar Value: _____

Year Completed: _____ Project Manager: _____

SECTION 2 -- TO BE COMPLETED BY THE CUSTOMER REFERENCE AND MAILED, HAND-DELIVERED OR FAXED DIRECTLY TO:

U.S. Army Corps of Engineers, Seattle District
 Attn: CENWS-CT-CB-MU - Attn: Kevin T Mulvihill
 P.O. Box 3755
 Seattle, WA 98124-3755

FAX: (206) 764-6817
 Street Address:
 4735 E. Marginal Way S.
 Seattle WA 98134-2385

Forms submitted by other than the customer (i.e., by the offeror), will not be considered.

OVERVIEW: The firm shown above has submitted a proposal on a Seattle District Corps of Engineers project and provided your name as a customer reference. Part of our evaluation process requires information on the firm's past performance. Your input is important to us and responses are required no later than the time and date proposals are due for inclusion in our evaluation.

Name of Individual completing survey: _____

Firm Name: _____ Phone Number: _____

Relationship to this Project: _____

The Following Chart depicts the rating that are to be used to evaluate the contractor's performance:

O	AA	S	M	U
Outstanding	Above Average	Satisfactory	Marginal	Unsatisfactory
Performance met all contract requirements and exceeded expectations. Problems, if any, were negligible, and were resolved in a timely and highly effective manner.	Performance met all contract requirements and exceeded some. There were a few minor problems which the contractor resolved in a timely, effective manner.	Performance met contract requirements. There were some minor problems, and corrective actions taken by the contractor were satisfactory.	Performance did not meet some contractual requirements. There were problems, some of a serious nature, for which corrective action was only marginally effective.	Performance did not meet contractual requirements. There were serious problems, and the contractor's corrective actions were ineffective.

BID SCHEDULE					
ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	<u>BASE PERIOD</u>				
	PROVIDE ALL SUPERVISION, LABOR, PARTS, AND MATERIALS FOR FIRE ALARM MAINTENANCE, REPAIR AND INSPECTION SERVICES AT FORT LEWIS, WA. IN STRICT ACCORDANCE WITH SPECIFICATION NO.				
	<u>FIXED ITEMS</u>				
0001	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled With an X	12	MO		
	TOTAL FIXED ITEMS - BASE PERIOD				
	<u>REQUIREMENTS ITEMS</u>				
0002	Parts and Material: Provide additional parts and material and other items and services necessary to test and maintain installed fire alarm systems in excess of the \$2,000 limitation in CLIN 0001, at Fort Lewis, WA. *Parts are not to exceed \$3,000 per facility.	10	EA		
	TOTAL REQUIREMENTS ITEMS - BASE PERIOD				
	<u>OPTIONAL ITEMS</u>				
0003	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number one (1)	12	MO		
0004	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number two (2)	12	MO		

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	OPTIONAL ITEMS				
0005	Fire Alarm Systems Testing and Maintenance:	12	MO		
	Provide all supervision, personnel, equipment,				
	parts*, transportation, and other items and services				
	necessary to inspect, test and maintain installed				
	fire alarm systems at Fort Lewis, WA.				
	In accordance with SOW, Section 1.				
	*Parts are not to exceed \$2,000 per facility.				
	See Appendix D labeled Number three (3)				
	TOTAL OPTIONAL ITEMS -BASE PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - BASE PERIOD				

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	FIRST OPTION PERIOD				
	PROVIDE ALL SUPERVISION, LABOR, PARTS, AND MATERIALS FOR FIRE ALARM MAINTENANCE, REPAIR AND INSPECTION SERVICES AT FORT LEWIS, WA. IN STRICT ACCORDANCE WITH SPECIFICATION NO.				
	FIXED ITEMS				
1001	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled With an (X)	12	MO		
	TOTAL FIXED ITEMS - FIRST OPTION PERIOD				
	REQUIREMENTS ITEMS				
1002	Parts and Material: Provide additional parts and material and other items and services necessary to test and maintain installed fire alarm systems in excess of the \$2,000 limitation in CLIN 0001, at Fort Lewis, WA. *Parts are not to exceed \$3,000 per facility.	10	EA		
	TOTAL REQUIREMENTS ITEMS - FIRST OPTION PERIOD				
	OPTIONAL ITEMS				
1003	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number one (1)	12	MO		
1004	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number two (2)	12	MO		

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	OPTIONAL ITEMS				
1005	Fire Alarm Systems Testing and Maintenance:	12	MO		
	Provide all supervision, personnel, equipment,				
	parts*, transportation, and other items and services				
	necessary to inspect, test and maintain installed				
	fire alarm systems at Fort Lewis, WA.				
	In accordance with SOW, Section 1.				
	*Parts are not to exceed \$2,000 per facility.				
	See Appendix D labeled Number three (3)				
	TOTAL OPTIONAL ITEMS -FIRST OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - FIRST OPTION PERIOD				

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	SECOND OPTION PERIOD				
	PROVIDE ALL SUPERVISION, LABOR, PARTS, AND MATERIALS FOR FIRE ALARM MAINTENANCE, REPAIR AND INSPECTION SERVICES AT FORT LEWIS, WA. IN STRICT ACCORDANCE WITH SPECIFICATION NO.				
	FIXED ITEMS				
2001	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled with an (X)	12	MO		
	TOTAL FIXED ITEMS - SECOND OPTION PERIOD				
	REQUIREMENTS ITEMS				
2002	Parts and Material: Provide additional parts and material and other items and services necessary to test and maintain installed fire alarm systems in excess of the \$2,000 limitation in CLIN 0001, at Fort Lewis, WA. *Parts are not to exceed \$3,000 per facility.	10	EA		
	TOTAL REQUIREMENTS ITEMS - SECOND OPTION PERIOD				
	OPTIONAL ITEMS				
2003	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number one (1)	12	MO		
2004	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number two (2)	12	MO		

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	OPTIONAL ITEMS				
2005	Fire Alarm Systems Testing and Maintenance:	12	MO		
	Provide all supervision, personnel, equipment,				
	parts*, transportation, and other items and services				
	necessary to inspect, test and maintain installed				
	fire alarm systems at Fort Lewis, WA.				
	In accordance with SOW, Section 1.				
	*Parts are not to exceed \$2,000 per facility.				
	See Appendix D, labeled Number three (3)				
	TOTAL OPTIONAL ITEMS - SECOND OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - SECOND OPTION PERIOD				

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	THIRD OPTION PERIOD				
	PROVIDE ALL SUPERVISION, LABOR, PARTS, AND MATERIALS FOR FIRE ALARM MAINTENANCE, REPAIR AND INSPECTION SERVICES AT FORT LEWIS, WA. IN STRICT ACCORDANCE WITH SPECIFICATION NO.				
	FIXED ITEMS				
3001	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix, D labeled with an (X)	12	MO		
	TOTAL FIXED ITEMS - THIRD OPTION PERIOD				
	REQUIREMENTS ITEMS:				
3002	Parts and Material: Provide additional parts and material and other items and services necessary to test and maintain installed fire alarm systems in excess of the \$2,000 limitation in CLIN 0001, at Fort Lewis, WA. *Parts are not to exceed \$3,000 per facility.	10	EA		
	TOTAL REQUIREMENTS ITEMS - THIRD OPTION PERIOD				
	OPTIONAL ITEMS				
3003	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled Number one (1)	12	MO		
3004	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled Number two (2)	12	MO		

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	OPTIONAL ITEMS				
3005	Fire Alarm Systems Testing and Maintenance:	12	MO		
	Provide all supervision, personnel, equipment,				
	parts*, transportation, and other items and services				
	necessary to inspect, test and maintain installed				
	fire alarm systems at Fort Lewis, WA.				
	In accordance with SOW, Section 1.				
	*Parts are not to exceed \$2,000 per facility.				
	See Appendix D, labeled Number three (3)				
TOTAL OPTIONAL ITEMS - THIRD OPTION PERIOD					
TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - 3RD OPTION PERIOD					

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	FOURTH OPTION PERIOD				
	PROVIDE ALL SUPERVISION, LABOR, PARTS, AND MATERIALS FOR FIRE ALARM MAINTENANCE, REPAIR AND INSPECTION SERVICES AT FORT LEWIS, WA. IN STRICT ACCORDANCE WITH SPECIFICATION NO.				
	FIXED ITEMS				
4001	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled with an (X)	12	MO		
	TOTAL FIXED ITEMS - FOURTH OPTION PERIOD				
	REQUIREMENTS ITEMS:				
4002	Parts and Material: Provide additional parts and material and other items and services necessary to test and maintain installed fire alarm systems in excess of the \$2,000 limitation in CLIN 0001, at Fort Lewis, WA. *Parts are not to exceed \$3,000 per facility.	10	EA		
	TOTAL REQUIREMENTS ITEMS - FOURTH OPTION PERIOD				
	OPTIONAL ITEMS				
4003	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled Number one (1)	12	MO		
4004	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D, labeled Number TWO (2)	12	MO		

This page intentionally blank

ITEM	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	OPTIONAL ITEMS				
4005	Fire Alarm Systems Testing and Maintenance: Provide all supervision, personnel, equipment, parts*, transportation, and other items and services necessary to inspect, test and maintain installed fire alarm systems at Fort Lewis, WA. In accordance with SOW, Section 1. *Parts are not to exceed \$2,000 per facility. See Appendix D labeled Number three (3)	12	MO		
	TOTAL OPTIONAL ITEMS - FOURTH OPTION PERIOD				
	TOTAL FIXED + OPTIONAL + REQUIREMENTS (ITEMS) - FOURTH OPTION PERIOD				
	SCHEDULE TOTALS				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - BASE PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - FIRST OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - SECOND OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - THIRD OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) - FOURTH OPTION PERIOD				
	TOTAL FIXED + REQUIREMENTS + OPTIONAL (ITEMS) BASE PLUS ALL OPTION PERIODS				

This page intentionally blank

FACP INFORMATION BY BLDG TYPE & SERVICE SCHEDULE									
BLDG NO	XMTR		FACILITY	SERVICED	SERVICE DUE				
					2003	2004	2005	2006	2007
01010	184	ADM	HQ GOLD STRIKE ROTC		2	2	2	2	2
02012	139	ADM	DPW		2	2	2	2	2
02015	138	ADM	CPO / DOC / USACE		2	2	2	2	2
02025	060	ADM	POST HQ	Jul-00	3	X	X	X	X
02025A	309	ADM	GENERALS HQ	Jul-00	3	X	X	X	X
02027	089	ADM	JAG & DRM	Jul-00	2	2	2	2	2
02140	061	ADM	WALLER HALL		X	X	X	X	X
02150	331	ADM	HOUSING	May-00	2	2	2	2	2
03026	045	ADM	ADMIN	Aug-00	2	2	2	2	2
03065	048-7	ADM	AIRFIELD	Aug-00	2	2	2	2	2
03077	048-6	ADM	AIRFIELD	Aug-00	2	2	2	2	2
03148	178	ADM	9TH CAV AIR ATTACK	Nov-00	2	2	2	2	2
03243	216	ADM	HQ 62ND MED GRP	Nov-00	2	2	2	2	2
03328	166	ADM	BN HQ	Oct-00	2	2	2	2	2
03651	140	ADM	BN HQ	Sep-02	2	2	2	2	2
03659	165	ADM	BN HQ	Feb-01	2	2	2	2	2
03670	180	ADM	BN HQ	Jan-01	2	2	2	2	2
03672	177	ADM	ADMIN	Oct-02	2	2	2	2	2
03674	179	ADM	ADMIN	Aug-02	2	2	2	2	2
03733	107	ADM	BRIGADE HQ	Sep-02	2	2	2	2	2
03743	112	ADM	BN HQ	Sep-02	2	2	2	2	2
03745	LOCAL	ADM	BN HQ	Sep-02	2	2	2	2	2
03746	LOCAL	ADM	BN HQ		2	2	2	2	2
03758	120	ADM	ORDERLY ROOM	Aug-02	2	2	2	2	2
04076	070-1	ADM	@ DPCA	Dec-00	2	2	2	2	2
04079	070	ADM	MWR MARKETING	Dec-00	2	2	2	2	2
04174	099	ADM	FINANCE DEPT	Jan-01	2	2	2	2	2
04290	333	ADM	5TH ARMY WEST HQ	Feb-01	2	2	2	2	2
04320	006	ADM	MUSEUM	Mar-01	X	X	X	X	X
05164	009	ADM	TRANSITION PT.	Feb-01	2	2	2	2	2
06231	063	ADM	66TH AVIATION HQ	Jan-01	2	2	2	2	2
09031	206	ADM		Feb-01	2	2	2	2	2
09116	162	ADM	HQ 201ST MI BD	Aug-02	2	2	2	2	2
9142	363	ADM	Language Lab		2	2	2	2	2
09160	236-1	ADM	BN HQ SIMONS HALL	Jun-02	2	2	2	2	2
09162	226-1	ADM	BN HQ MADDING HALL	Jul-02	2	2	2	2	2
09177	226-2	ADM	CO HQ	Jun-02	2	2	2	2	2
09178	236-2	ADM	CO HQ	Jul-02	2	2	2	2	2
09181	236-4	ADM	CO HQ	Jun-02	2	2	2	2	2
09190	236-5	ADM	BN HQ	Jul-02	2	2	2	2	2
12228	346	ADM	BN HQ	Jul-00	2	2	2	2	2
12235	345	ADM	BRIGADE HQ		2	2	2	2	2
12248	344	ADM	BN HQ	Aug-00	2	2	2	2	2
12321	347	ADM	COS	Jun-00	2	2	2	2	2
12324	317	ADM	B CO/SUP	Jun-00	2	2	2	2	2
12327	316	ADM	A CO/SUP	Jun-00	2	2	2	2	2

This page intentionally blank

12341	343	ADM	COS	Jun-00	2	2	2	2	2
12344	319	ADM	D CO/SUP	Jun-00	2	2	2	2	2
12347	318	ADM	C CO/SUP	Jun-00	2	2	2	2	2
12731	323	ADM	C CO/SUP	Jul-00	2	2	2	2	2
12734	324	ADM	B CO/SUP	Nov-00	2	2	2	2	2
12737	325	ADM	A CO/SUP	Jul-00	2	2	2	2	2
12741	351	ADM	COS	Oct-00	2	2	2	2	2
12744	352	ADM	COS	Oct-00	2	2	2	2	2
12747	353	ADM	CO HQ	Sep-00	2	2	2	2	2
12821	326	ADM	BN HQ	Aug-00	2	2	2	2	2
12835	355	ADM	BRIGADE HQ	Jul-00	2	2	2	2	2
12841	354	ADM	BN HQ	Aug-00	2	2	2	2	2
12957	T200	ADM	ADMIN		2	2	2	2	2
12958	T200	ADM	ADMIN		2	2	2	2	2
12959	T200	ADM	ADMIN		2	2	2	2	2
12960	T200	ADM	ADMIN		2	2	2	2	2
12967	T200	ADM	ADMIN		2	2	2	2	2
12969	T200	ADM	ADMIN		2	2	2	2	2
B0808	191	ADM	NF		2	2	2	2	2
B0809	196	ADM	NF		2	2	2	2	2
B0812	305	ADM	ADMIN		2	2	2	2	2
B0833	197	ADM	NF		2	2	2	2	2
M0001	329	ADM	ASP ADMIN		2	2	2	2	2
01034	217-3	BEQ	BEQ		X	1	X	1	X
01036	217	BEQ	BEQ		X	1	X	1	X
01037	217-2	BEQ	BEQ		3	1	X	1	X
02006	106	BKS	ADMIN/BARRACKS NEW SYS	Jul-00	3	1	X	1	X
02007	237	BKS	ADMIN/BARRACKS NEW SYS		3	1	X	1	X
02008	117	BKS	ADMIN/BARRACKS NEW SYS		X	1	X	1	X
02013	143	ADM	DCA		2	2	2	2	2
02019	141	BKS	ADMIN/BARRACKS NEW SYS		3	1	X	1	X
02020	187	BKS	ADMIN/BARRACKS NEW SYS		3	1	X	1	X
02021	142	BKS	ADMIN/BARRACKS NEW SYS		3	1	X	1	X
02026	058	BKS	BARRACKS		X	1	X	1	X
02110	080	BOQ	Fort Lewis Lodge		X	X	X	X	X
2111	080	BOQ	Fort Lewis Lodge	Sep-01	X	1	X	1	X
03114	244	BKS	BARRACKS	Sep-01	X	1	X	1	X
03115	245	BKS	BARRACKS	Sep-01	X	1	X	1	X
03116	246	BKS	BARRACKS	Sep-01	X	1	X	1	X
03118	247	BKS	BARRACKS	Sep-01	X	1	X	1	X
03119	248	BKS	BARRACKS	Sep-01	X	1	X	1	X
03121	249	BKS	BARRACKS	Nov-01	X	1	X	1	X
03122	250	BKS	BARRACKS	Nov-01	X	1	X	1	X
03123	144	BKS	BARRACKS	Sep-01	X	1	X	1	X
03124	251	BKS	BARRACKS	Sep-01	X	1	X	1	X
03156	252	BKS	BARRACKS	Sep-01	X	1	X	1	X
03157	253	BKS	BARRACKS	Sep-01	X	1	X	1	X
03158	254	BKS	BARRACKS	Oct-01	X	1	X	1	X
03160	255	BKS	BARRACKS	Sep-01	X	1	X	1	X

This page intentionally blank

03161	131	BKS	BARRACKS	Sep-01	X	1	X	1	X
03163	256	BKS	BARRACKS	Oct-01	X	1	X	1	X
03164	132	BKS	BARRACKS	Sep-01	X	1	X	1	X
03165A	260	BKS	BARRACKS	Oct-01	X	1	X	1	X
03165B	198	BKS	BARRACKS	Oct-01	X	1	X	1	X
03165C	257	BKS	BARRACKS	Oct-01	X	1	X	1	X
03213	283	BKS	BARRACKS	Oct-01	X	1	X	1	X
03214	284	BKS	BARRACKS	Oct-01	X	1	X	1	X
03215	285	BKS	BARRACKS	Oct-01	X	1	X	1	X
03216	286	BKS	BARRACKS		X	1	X	1	X
03218	134	BKS	BARRACKS (320H)		X	1	X	1	X
03219	134-1	BKS	BARRACKS	Nov-01	X	1	X	1	X
03221	287	BKS	BARRACKS	Nov-01	X	1	X	1	X
03222	288	BKS	BARRACKS	Nov-01	X	1	X	1	X
03223	289	BKS	BARRACKS	Nov-01	X	1	X	1	X
03224	290	BKS	BARRACKS	Oct-01	X	1	X	1	X
03278	296	BKS	BARRACKS	Oct-01	X	1	X	1	X
03279	128	BKS	BARRACKS(320)	Oct-01	X	1	X	1	X
03280	124	BKS	BARRACKS	Oct-01	X	1	X	1	X
03281	129	BKS	BARRACKS(320)	12/2001	X	1	X	1	X
03283	312	BKS	BARRACKS	Nov-01	X	1	X	1	X
03284	133	BKS	BARRACKS (320)	Nov-01	X	1	X	1	X
03286	291	BKS	BARRACKS	Nov-01	X	1	X	1	X
03287	292	BKS	BARRACKS	Oct-01	X	1	X	1	X
03288	293	BKS	BARRACKS	Oct-01	X	1	X	1	X
03413	262	BKS	BARRACKS	12/2001	X	1	X	1	X
03414	263	BKS	BARRACKS	Nov-01	X	1	X	1	X
03415	264	BKS	BARRACKS	Nov-01	X	1	X	1	X
03416	265	BKS	BARRACKS	12/2001	X	1	X	1	X
03417	266	BKS	BARRACKS	12/2001	X	1	X	1	X
03418	267	BKS	BARRACKS	12/2001	X	1	X	1	X
03419	268	BKS	BARRACKS	12/2001	X	1	X	1	X
03420	269	BKS	BARRACKS	12/2001	X	1	X	1	X
03421	270	BKS	BARRACKS	12/2001	X	1	X	1	X
03422	271	BKS	BARRACKS	12/2001	X	1	X	1	X
03469	272	BKS	BARRACKS	Dec-00	X	1	X	1	X
03470	273	BKS	BARRACKS	Dec-00	X	1	X	1	X
03474	274	BKS	BARRACKS	Nov-00	X	1	X	1	X
03475	275	BKS	BARRACKS	Nov-00	X	1	X	1	X
03653	233	BKS	BARRACKS	Dec-00	X	1	X	1	X
03654	239	BKS	BARRACKS	Oct-02	3	1	X	1	X
03655	145	BKS	BARRACKS	Sep-02	3	1	X	1	X
03656	077	BKS	BARRACKS	Dec-00	3	1	X	1	X
03657	016	BKS	BARRACKS	Oct-02	3	1	X	1	X
03761	105	BKS	BARRACKS	Sep-02	3	1	X	1	X
03762	127	BKS	BARRACKS	Sep-02	3	1	X	1	X
03763	115	BKS	BARRACKS	Sep-02	3	1	X	1	X
03764	109	BKS	BARRACKS	Sep-02	3	1	X	1	X
03765	110	BKS	BARRACKS	Sep-02	3	1	X	1	X

This page intentionally blank

03766	119	BKS	BARRACKS	Sep-02	3	1	X	1	X
09175	226-3	BKS	SF BARRACKS	Jul-02	3	1	X	1	X
09176	226-5	BKS	SF BARRACKS	Jul-02	3	1	X	1	X
9901	096	BKS	BARRACKS		3	1	X	1	X
09906	096	BKS	BARRACKS		3	1	X	1	X
12418	156	BKS	B CO BARRACKS		X	1	X	1	X
12435	348	BKS	BARRACKS		X	1	X	1	X
12458	161	BKS	A BARRACKS		X	1	X	1	X
12603	321	BKS	A BARRACKS		X	1	X	1	X
12630	349	BKS	BARRACKS	Feb-01	X	1	X	1	X
12663	322	BKS	B BARRACKS		X	1	X	1	X
A0112	135	BKS	BARRACKS		X	1	X	1	X
A0124	146	BKS	BARRACKS		X	1	X	1	X
A0132	173	BKS	BARRACKS		X	1	X	1	X
A0133	136	BKS	BARRACKS		X	1	X	1	X
A0506	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0507	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0536	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0537	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0606	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0607	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0632	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0636	LOCAL	BKS	BARRACKS		X	1	X	1	X
A0637	LOCAL	BKS	BARRACKS		X	1	X	1	X
B0405	150-4	BKS	BARRACKS		X	1	X	1	X
B0407	150-3	BKS	BARRACKS		X	1	X	1	X
B0408	150-2	BKS	BARRACKS		X	1	X	1	X
B0409	150	BKS	BARRACKS		X	1	X	1	X
B0508	LOCAL	BKS	BARRACKS		X	1	X	1	X
B0532*	170	BKS	NF, * TRANSMITTER NOT HOOKED UP		X	1	X	1	X
B0533*	170-3	BKS	NF, * TRANSMITTER NOT HOOKED UP		X	1	X	1	X
B0607	170-4	BKS	BARRACKS		X	1	X	1	X
B0608	171-5	BKS	BARRACKS		X	1	X	1	X
B0609	170-5	BKS	BARRACKS		X	1	X	1	X
A0707	164	BKS	BARRACKS		X	1	X	1	X
B0732	LOCAL	BKS	BARRACKS		1	X	1	X	1
B0733	LOCAL	BKS	BARRACKS		1	X	1	X	1
B0803	214-3	BKS	BARRACKS		1	X	1	X	1
B0804	214	BKS	BARRACKS		1	X	1	X	1
B0805	214-1	BKS	BARRACKS		1	X	1	X	1
B0820	215-4	BKS	BARRACKS		1	X	1	X	1
B0821	215-5	BKS	BARRACKS		1	X	1	X	1
B0822	215	BKS	BARRACKS		1	X	1	X	1
B0827	215-1	BKS	BARRACKS		1	X	1	X	1
B0828	215-2	BKS	BARRACKS		1	X	1	X	1
B0829	215-3	BKS	BARRACKS		1	X	1	X	1
C0306	193	BKS	BARRACKS		1	X	1	X	1
C0526	167-6	BKS	BARRACKS		1	X	1	X	1
C0702	167-4	BKS	BARRACKS		1	X	1	X	1

This page intentionally blank

C0703	167-5	BKS	BARRACKS		1	X	1	X	1
C0706	167	BKS	BARRACKS		1	X	1	X	1
C0707	167-2	BKS	BARRACKS		1	X	1	X	1
C0722	LOCAL	BKS	BARRACKS		1	X	1	X	1
C0723	167-1	BKS	BARRACKS		1	X	1	X	1
C0902	LOCAL	BKS	BARRACKS		1	X	1	X	1
C0903	168-5	BKS	BARRACKS		1	X	1	X	1
C0906	168-6	BKS	BARRACKS		1	X	1	X	1
C0922	168-1	BKS	BARRACKS		1	X	1	X	1
C0923C	168-2	BKS	BARRACKS		1	X	1	X	1
C0926	168	BKS	BARRACKS		1	X	1	X	1
C0927	LOCAL	BKS	BARRACKS		1	X	1	X	1
C1026	169	BKS	BARRACKS		1	X	1	X	1
C1224	053	BKS	BARRACKS		1	X	1	X	1
C1227	172	BKS	BARRACKS		1	X	1	X	1
C1333	169-3	BKS	BARRACKS		1	X	1	X	1
C1334	169-2	BKS	BARRACKS		1	X	1	X	1
D0304	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0305	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0306	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0307	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0308	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0309	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0330	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0331	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0332	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0333	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0504	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0506	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0509	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0528	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0529	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0530	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0531	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0532	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0533	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0604	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0605	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0606	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0607	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0608	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0609	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0628	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0629	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0630	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0631	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0632	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0633	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0704	LOCAL	BKS	BARRACKS		1	X	1	X	1

This page intentionally blank

D0705	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0706	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0707	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0708	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0709	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0728	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0729	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0730	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0731	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0732	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0733	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0804	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0805	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0806	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0807	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0808	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0809	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0828	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0829	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0830	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0831	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0832	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0833	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0903	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0904	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0905	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0906	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0913	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0914	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0933	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0940	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0940	LOCAL	BKS	BARRACKS		1	X	1	X	1
D0948	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1106	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1117	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1118	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1143	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1158	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1159	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1160	LOCAL	BKS	BARRACKS		1	X	1	X	1
D1163	LOCAL	BKS	BARRACKS		1	X	1	X	1
DO328	LOCAL	BKS	BARRACKS		1	X	1	X	1
DO329	LOCAL	BKS	BARRACKS		1	X	1	X	1
DO505	LOCAL	BKS	BARRACKS		1	X	1	X	1
DO507	LOCAL	BKS	BARRACKS		1	X	1	X	1
DO508	LOCAL	BKS	BARRACKS		1	X	1	X	1
SPARE	171	BKS	BARRACKS		1	X	1	X	1
01020	294	BOQ	BRONSON HALL		X	X	X	X	X
02111	160	BOQ	FT LEWIS LODGE		X	X	X	X	X

This page intentionally blank

02492	158	BOQ	BARRACKS		1	X	1	X	1
02493	163	BOQ	BARRACKS		1	X	1	X	1
02095	230	CDC	CHILD DEVELOPMENT CNTR		X	X	X	X	X
06995	234	CDC	CHILD DEVELOPMENT CNTR		X	X	X	X	X
08300	232	CDC	CHILD DEVELOPMENT CNTR		X	X	X	X	X
02072	149	COM	LIGHTHOUSE FOR THE BLIND		2	2	2	2	2
02202	277	COM	MINI-MALL		X	X	X	X	X
02204	310	COM	FIRESTONE	Jun-00	2	2	2	2	2
05170	103	COM	THRIFT SHOP	Jan-01	2	2	2	2	2
05172	103-1	COM	THRIFT SHOP	Jan-01	2	2	2	2	2
05275	152	COM	COMMISARY		X	X	X	X	X
05280	073	COM	POST EXCHANGE		X	X	X	X	X
06071	301	COM	PHONE BLDG	Mar-01	2	2	2	2	2
09052	205	COM	SHOPPETTE @ MADIGAN		2	2	2	2	2
12570	194	COM	RSU/TELEPHONE	May-00	2	2	2	2	2
A1006	295	COM	NF MINI-MALL		X	X	X	X	X
03757	126	DF	DINING FACILITY	Aug-02	2	2	2	2	2
09179	226	DF	DINING FACILITY	Jun-02	2	2	2	2	2
12430	320	DF	DINING FACILITY		2	2	2	2	2
12638	350	DF	DINING FACILITY		2	2	2	2	2
C0327	195	DF	DINING FACILITY		2	2	2	2	2
C0928	168-4	DF	DINING FACILITY		2	2	2	2	2
06242	041	EF	STONE EDUCATION CNTR	May-00	X	X	X	X	X
	313	EMS	FLFD PORTABLE	Aug-00	2	2	2	2	2
03081	LOCAL	EMS	FIRE STA. 2		2	2	2	2	2
01529	299-5	FS	GOLF COURSE CLUB HOUSE		X	X	X	X	X
02260	207	FS	POPEYES	Jun-00	X	X	X	X	X
02265	298	FS	BURGER KING	Jun-00	X	X	X	X	X
08085	011	FS	NCO CLUB (WET SPKLR)		X	X	X	X	X
08981	332	FS	MARINA RESTRUANT	Mar-01	2	2	2	2	2
03204	055	MED	DENTAL CLINIC (MH)	Oct-00	2	2	2	2	2
09678	315	MF	Parachute Rigging		2	2	2	2	2
09900	212	MED	MADIGAN ADMIN		2	2	2	2	2
01210	097	MF	DPW ENVIRONMENTAL	May-00	2	2	2	2	2
01401	137	MF	TASC	May-00	2	2	2	2	2
01517	081	MF	GOLF COURSE MAINT BLDG	May-00	2	2	2	2	2
01521	299	MF	GOLF CART MAINT	May-00	2	2	2	2	2
02043	074-2	MF	DPW SHOP	Nov-00	2	2	2	2	2
02045	001	MF	SHOP TEST		2	2	2	2	2
02047	190-3	MF	PW HAZ STORAGE	Nov-00	2	2	2	2	2
02054	075	MF	DPW MAINT	Nov-00	2	2	2	2	2
03025	221	MF	HANGAR	Aug-00	X	X	X	X	X
03035	282	MF	PAINT BOOTH	Jun-00	2	2	2	2	2
03036	079	MF	HANGAR	Aug-00	X	X	X	X	X
03041	046	MF	HANGAR	Aug-00	X	X	X	X	X
03052	047-1	MF	HANGAR	Aug-00	X	X	X	X	X
03063	224	MF	HANGAR	Aug-00	X	X	X	X	X
03075	048	MF	HANGAR	Aug-00	X	X	X	X	X
03098	050	MF	OLR HANGAR	Oct-00	X	X	X	X	X

This page intentionally blank

03106	027, 130	MF	ARMY RESERVE HANGER	May-02	X	X	X	X	X
03146	225	MF	HANGAR PUMP	May-02	2	2	2	2	2
03169	LOCAL	MF	MOTOR POOL		2	2	2	2	2
03209	210	MF	AIRFIELD RADIO TOWER	Sep-00	2	2	2	2	2
03272	030	MF	HANGAR (SPKLR)	Oct-00	X	X	X	X	X
03306	213	MF	MOTOR POOL	Oct-00	2	2	2	2	2
03317	188	MF	TRAILER	Oct-00 / Jun-02	2	2	2	2	2
03352	065	MF	MOTOR POOL	May-02	2	2	2	2	2
03378	278	MF	MOTOR POOL	Apr-02	2	2	2	2	2
03379	278-6	MF	MOTOR POOL	Apr-02	2	2	2	2	2
03380	278-5	MF	MOTOR POOL	Apr-02	2	2	2	2	2
03381	278-8	MF	MOTOR POOL	Apr-02	2	2	2	2	2
03382	278-7	MF	MOTOR POOL	Apr-02	2	2	2	2	2
03390	279	MF	MOTOR POOL	Aug-02	2	2	2	2	2
03426	219	MF	MOTOR POOL	Jun-02	2	2	2	2	2
03427	218	MF	MOTOR POOL	May-02	2	2	2	2	2
03644	051	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03751	049	MF	MOTOR POOL	Aug-02	2	2	2	2	2
03810	229	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03812	228-1	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03814	228-2	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03818	228-3	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03820	227-8	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03822	227	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03822	228	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03824	227-7	MF	MOTOR POOL		2	2	2	2	2
03901	052	MF	MOTOR POOL	Jan-01	2	2	2	2	2
03902	339	MF	MOTOR POOL	Feb-01	2	2	2	2	2
03907	338	MF	MOTOR POOL	Feb-01	2	2	2	2	2
03909	340	MF	MOTOR POOL	Feb-01	2	2	2	2	2
03916	223	MF	MOTOR POOL		2	2	2	2	2
03934	335	MF	MOTOR POOL	Mar-01	2	2	2	2	2
03945	220	MF	MOTOR POOL	Mar-01	2	2	2	2	2
03957	176	MF	MOTOR POOL	Feb-01	2	2	2	2	2
03960	071	MF	MOTOR POOL	Mar-01	2	2	2	2	2
03966	337	MF	MOTOR POOL	Mar-01	2	2	2	2	2
03967	341	MF	MOTOR POOL	Mar-01	2	2	2	2	2
03981	336	MF	MOTOR POOL	Feb-01	3	3	3	3	3
03985	182	MF	MOTOR POOL	Feb-01	3	3	3	3	3
03986	181	MF	MOTOR POOL	Feb-01	3	3	3	3	3
04061	076	MF	PEST CONTROL	Feb-01	3	3	3	3	3
09145	235	MF	MP MAINT BAY	Jun-02	3	3	3	3	3
09155	235-6	MF	PARACHUTE TOWER	Jun-02	3	3	3	3	3
09500	018	MF	COMPUTER BLDG		3	3	3	3	3
09503	017-5	MF	LOG CNTR, CPO		3	3	3	3	3
09523	017-3	MF	LOG CNTR		3	3	3	3	3
09540	068-3	MF	@ ARMY RESERVE/MAINT		3	3	3	3	3
09552	068-5	MF	@ ARMY RESERVE/WAREHOUSE		3	3	3	3	3
09580	019	MF	BASE SHOPS (SPKLR)		3	3	3	3	3

This page intentionally blank

09580	083	MF	BASE SHOPS		3	3	3	3	3
09583	036	MF	BATTERY SHOP		3	3	3	3	3
09592	018-7	MF	LOG CNTR		3	3	3	3	3
09620	201	MF	DOL(SPKLR ONLY)		3	3	3	3	3
09641	025	MF	TASC (SPKLR)		3	3	3	3	3
09645	025-3	MF	MILES (DRY SPKLR)		3	3	3	3	3
09674	159	MF	HAZARDOUS MTL @ DOL		3	3	3	3	3
09691	157-5	MF	NAV-MARINE/MAINT		3	3	3	3	3
09692	157-8	MF	NAV-MARINE/HAZMAT		3	3	3	3	3
09693	157-5	MF	NAV-MARINE/HAZMAT		3	3	3	3	3
11138	093	MF	E1405/MOTOR POOL		3	3	3	3	3
11166	102	MF	E1221/MOTOR POOL		3	3	3	3	3
11248	091	MF	E1307/MOTOR POOL		3	3	3	3	3
11504	086	MF	A1504/MOTOR POOL		3	3	3	3	3
A1491	174	MF	MOTOR POOL		3	3	3	3	3
02044	074	MF	DPW SHOP	Nov-00	3	3	3	3	3
03393	279-5	MF	SENTRY STATION	Aug-02	3	3	3	3	3
05183	311	MP	CID	Jan-01	3	3	3	3	3
09113	308	MP	SIGNAL INTELLIGENCE	Aug-02	3	3	3	3	3
02001	280	MS	MN POST CHAPEL		X	X	X	X	X
02004	189	MS	FRENCH THEATER		X	X	X	X	X
02022	057	MS	JENSEN GYM		X	X	X	X	X
02109	155	MS	LIBRARY		X	X	X	X	X
02161	241	MS	GYM @ CAREY THEATER		X	X	X	X	X
02163	062	MS	CAREY THEATER		X	X	X	X	X
02166	208	MS	TICKETS & TOURS	May-00	X	X	X	X	X
02272	359	MS	BOWLING ALLEY		X	X	X	X	X
02275	014	MS	ROLLER RINK		X	X	X	X	X
02295	242	MS	YOUTH CNTR		X	X	X	X	X
02400	059	MS	CASCADE COMMUNITY CNTR.		X	X	X	X	X
03236	151	MS	SOLDIERS FIELD HOUSE		X	X	X	X	X
03271	054	MS	LIBRARY		X	X	X	X	X
03646	185	ADM	USAF COMPOUND	Sep-02	3	3	3	3	3
03759	123	MS	GYM	Aug-02	3	X	X	X	X
03799	108	MS	CHAPEL	Aug-02	3	X	X	X	X
03969	356	MS	SKEET RANGE	Mar-01	3	3	3	3	3
04081	211	MS	AUTOCRAFT SHOP	Feb-01	3	3	3	3	3
04274	204	MS	FAMILY RESOURCE CNTR	Feb-01	X	X	X	X	X
08050	021	MS	NW ADVENTURE CNTR	Feb-01	X	X	X	X	X
08069	082	MS	CAMPGROUND		3	3	3	3	3
08197	013	MS	BEACHWOOD YOUTH CNTR	Nov-00	X	X	X	X	X
08274	010	MS	EM BEACH	Jan-01	3	3	3	3	3
08278	334	MS	BEACH CONTROL CNTR	Jan-01	3	3	3	3	3
08980	328	MS	MARINA BOAT MAINT.	Mar-01	3	3	3	3	3
09120	306	MS	4 CHAPLIN CHAPEL	Aug-02	3	X	X	X	X
09935	088	MS	CERAMIC/PET SHOP		3	3	3	3	3
09993	033	MS	GYM MADIGAN HOSPITAL		X	X	X	X	X
A0310	007	MS	NF GYM (DRY SPKLR)		X	X	X	X	X
B1216	032	MS	REC CENTER (SPKLR)		X	X	X	X	X

This page intentionally blank

02407	094	POL	STRYKER GAS STATION		3	3	3	3	3
03389	279-4	POL	POL	Aug-02	3	3	3	3	3
03392	279-2	POL	FUELING STATION	Aug-02	3	3	3	3	3
06038	304	POL	GAS SHOPETE	Mar-01	3	3	3	3	3
09588	231	POL	DOL CSRA		3	3	3	3	3
09636	028	POL	CONSOLIDATED FUEL STOR.		X	X	X	X	X
C0112	222	POL	OLD FUEL STATION		3	3	3	3	3
01315	004	RCF	RCF MAINTENANCE BLDG.		3	3	3	3	3
01324	043	RCF	MENTAL HEALTH CONF. FAC.	May-00	3	3	3	3	3
01325	042	RCF	WOOD SHOP CONF. FAC.	May-00	3	3	3	3	3
01450	064	RCF	STOCKADE	May-00	X	X	X	X	X
01450	101	RCF	STOCKADE	May-00	X	X	X	X	X
01451	101-1	RCF	@ STOCKADE	May-00	X	X	X	X	X
01452	101-2	RCF	@ STOCKADE		X	X	X	X	X
03086	078	TF	FLIGHT SIMULATOR	Jul-00	3	3	3	3	3
03087	183	TF	FLIGHT SIMULATOR	Oct-00	3	3	3	3	3
03203	148	TF	TSC TEST CNTR	Sep-00	3	3	3	3	3
03501	122	TF	TARGET TRAINER	Jun-02	3	3	3	3	3
09111	258	TF	SKIF	Aug-02	3	3	3	3	3
09532	068	TF	ARMY RESERVE CENTER		3	3	3	3	3
09608	238	TF	NAT'L GUARD CNTR		3	3	3	3	3
09690	157	TF	NAV-MARINE FAC		3	3	3	3	3
11732	327	TF	A1426/BATTLE SIMS		3	3	3	3	3
A0454	259-2	TF	TRAINING FACILITY		3	3	3	3	3
A0455	259	TF	TRAINING FACILITY		3	3	3	3	3
A0540	LOCAL	TF	TRAINING FACILITY		3	3	3	3	3
A1110	072	TF	BATTLE SIMS		3	3	3	3	3
A1112	072-5	TF	@ BATTLE SIMS		3	3	3	3	3
A1413	005	TF	BATTLE SIMS		3	3	3	3	3
A1451	008	TF	BATTLE SIMS (DRY SPKLR)		3	3	3	3	3
01523	044	UTL	GOLF COURSE PUMP HUSE	May-00	3	3	3	3	3
02160	062-3	UTL	BOILER PLANT		3	3	3	3	3
02895	297	UTL	UPGRADE XMTR TOWER	Jul-00	3	3	3	3	3
03054	047	UTL	PUMP HOUSE	Aug-00	3	3	3	3	3
03080	303	UTL	ASR RDR SITE (BILL 3080)	Oct-00	3	3	3	3	3
03095	314	UTL	INCINERATOR	Oct-00	3	3	3	3	3
07601	243	UTL	DUMP	Mar-01	3	3	3	3	3
07972	034	UTL	WATER PLANT	Dec-00	3	3	3	3	3
07974	034-4	UTL	@ WTR PLANT	Dec-00	3	3	3	3	3
07975	034-3	UTL	@ WTR PLANT	Dec-00	3	3	3	3	3
01411	066-3	WH	I CORPS STORAGE		3	3	3	3	3
03102	035	WH	ARMY RESERVE STORAGE		3	3	3	3	3
03113	342	WH	ARMY RESERVE STORAGE	Jun-02	3	3	3	3	3
03391	279-3	WH	STORAGE	Aug-02	3	3	3	3	3
03479	LOCAL	WH	RANGER STORAGE		3	3	3	3	3
03922	300	WH	SUPPLY @ MTR POOL	Feb-01	3	3	3	3	3
04078	070-2	WH	WAREHOUSE	Dec-00	3	3	3	3	3
04170	070-3	WH	@ DPCA	Dec-00	3	3	3	3	3
04172	070-6	WH	@ DPCA	Dec-00	3	3	3	3	3

This page intentionally blank

This page intentionally blank

PREPROPOSAL SITE VISIT

TITLE: FIRE ALARM INSPECTION, TESTING AND MAINTENANCE
LOCATION: FORT LEWIS, WASHINGTON
SOLICITATION: DACA67-03-R-0206
DATE: 21 February 2003

Attendance Roster

Name	E-mail Address	Organization	Phone
Bill Byers	byersb@lewis.army.mil	PW,ECMD	253-966-1715
Dan Frey	Freyd@lewis.army.mil	PW,ECMD	253-966-1722
Newell Flood	jnflood@attbi.com	Newell Consulting	360-438-2337
Ralph Frum	RFRUM1@AOL.COM	Norse Construction Services	360-402-6474
Troy Paddock	tpaddock@avaloncontracting.com	Avalon Contracting	253-383-4559
Steven Roening	steve@evergreenfirealms.net	Evergreen Fire Alarms	253-627-3794
Eric Hamerski	ErikHamerski@d-tech.com	D-Tech div of Gaurdian	360-647-0110
Carl Hunter		Cascade Fire	509-727-4645
David Alvord	dalvord@guardiansecurity.com	D-Tech div of Gaurdian	360-647-0110
Larry Romaine	larry@psintegrated.com	Performance systems	503-641-2222
Joel Christiansen	joel@advancedsolutionsgroup.biz	Advanced solutions group	801-444-0029
Scott Dulaney	scott@psintegrated.com	Performance Systems	503-641-2222
Joel Sacho	joel@suppression.com	Suppressions Systems	253-926-3300

This page intentionally blank

Meeting Minutes

Subject: Preproposal Site Visit
Contract: Fire Alarm Testing, Inspection, and Maintenance
Location: Fort Lewis, Washington
Contract No: DACA67-03-R-0206

We had our Pre Award Meeting on February 21, 2003 at building 2012 in room 219 where we reviewed the Statement of work and were asked a few questions that will be noted below. The Present potential bidders were informed that if they had any questions, they were to put them in writing and to forward them to Army Corps of Engineers, Contract Specialist Kevin T. Mulvihill. I also informed them the reason to submit there questions in writing was so that everyone would have the same information. The Quality Assurance Evaluator (Dan Frey) And I commenced our On site visit to give potential bidders a good idea, and representative of what kind of systems we have, to include a good variety of buildings that are to be Serviced on Fort Lewis, Washington.

Answers are given below to the questions that were asked by the attendees of the site visit noted above. The answers below are for clarification purposes only and do not change the contents, terms or conditions of the solicitation in any way.

Q: Is the Contractor responsible for testing HALON or AFFF systems in conjunction with Fire Alarm Control Panels (FACP)?

A: No, the only test to be performed on these systems is the link between them and The FACP. For example, testing the wiring interconnect to make sure simulated activation of the HALON or AFFF Systems triggers the FACP.

Q: Is sensitivity testing to be performed on each device?

A: Yes, regardless of if the device is addressable and generates it's own test data, sensitivity testing will be performed on each device.

Q: What is meant by cleaning each device?

A: Each device will be opened if designed to be opened, smoke chambers will be replaced, and units will be either vacuumed or blown out with canned air and reassembled.

Q: Will a vertical lift be provided to reach devices in hangers and motor pools?

A: No, the Contractor is responsible for providing a vertical lift.

Q: Is the Contractor responsible for repairing the kingfisher transmitters?

A: No, several transmitters are available through the Public Works Fire Alarm Shop, The Contractor can coordinate with the Fire Alarm Shop for transmitter replacement by either the contractor or the Fire Alarm Shop.

Q: Will the Government schedule the buildings to be tested with the building occupants?

A: No, the Contractor will be responsible for scheduling testing with the building occupant as well as ensuring no interference with occupants day to day routine takes place.

Q: Will the Government assist in access issues?

A: If the issue is keys for buildings, we will assist in getting the keys needed.
If the issue is due to security considerations we will also assist in access.

Q: In buildings with suppression systems, what are the procedures?

A: The Public Works Sprinkler Shop will be notified at least 48 hrs in advance so the System can be secured. Once work is completed the suppression system will be restored By the Public Works Sprinkler Shop.

Q: What type of drawings will the contractor be required to provide for each building?

A: A sample drawing will be sent upon request to the Contractor.